
ELECTRO-MECH SCOREBOARD CO.

<i>BATTER</i>	<i>BALL</i>	<i>STRIKE</i>	<i>OUT</i>	<i>H</i>									
00	0	0	0	00									
<i>GUEST</i>	<i>1</i>	<i>2</i>	<i>3</i>	<i>4</i>	<i>5</i>	<i>6</i>	<i>7</i>	<i>8</i>	<i>9</i>	<i>10</i>	<i>RUNS</i>	<i>HITS</i>	<i>ERRORS</i>
	0	0	0	0	0	0	0	0	0	0	00	00	0
<i>HOME</i>	0	0	0	0	0	0	0	0	0	0	00	00	0

1550 BASEBALL SCOREBOARD

OWNER'S HANDBOOK

Thank you for choosing an Electro-Mech Scoreboard for your athletic complex. We are confident that your new scoreboard will give many years of reliable service.

Rev. 8 Revised: 02/09/06

TABLE OF CONTENTS

1550 BASEBALL SCOREBOARD SPECIFICATIONS.....	3
SCOREBOARD INSTALLATION	4
MECHANICAL INSTALLATION	4
Post Installation	4
Mounting The Scoreboard	7
MOUNTING HARDWARE	7
Mounting The Optional Side Sponsor Panel	9
Mounting The Optional Top Sponsor Panel	9
ELECTRICAL INSTALLATION	9
Ground Connection.....	9
Power Connections to Upper Scoreboard Cabinet	10
Control Cable Connections to Upper Scoreboard Cabinet	10
Power Connection to Scoreboard	11
ScoreLink 300.....	12
Control Cable Installation.....	12
Control Console Connections.....	13
Control Console Safety Warning.....	13
SCOREBOARD OPERATION.....	13
SCOREBOARD STARTUP.....	13
GAME TIME OPERATION	13
Control Console Key Functions.....	15
SCOREBOARD SHUTDOWN.....	18
SERVICING THE SCOREBOARD	18
TROUBLESHOOTING TIPS	18
COMPONENT REPLACEMENT	18
LED Digits And Indicators Replacement.....	19
LED Digit Driver - Large Board Replacement	21
LED Driver Modules Replacement.....	23
LED Power Supply Modules Replacement	26
LED Power Interface Board Replacement	26
WARRANTY	29

1550 BASEBALL SCOREBOARD SPECIFICATIONS

GENERAL: This ETL listed scoreboard includes the scoreboard cabinet, mounting hardware, control console, control cable (sold separately), 10 ft. extension cable, and junction box.

DIMENSIONS: 26' L x 9' H x 6" D (top cabinet: 26' x 4' x 6", bottom cabinet: 26' x 5' x 6")

WEIGHT: 800 lbs (top cabinet: 300 lbs, bottom cabinet: 500 lbs)

SCOREBOARD CONSTRUCTION: The scoreboard consists of two cabinets. The frame is made from extruded aluminum. The face and back are made from aluminum sheet. The face and masks are finished with enamel paint. Black is the standard color. The captions are white on a gray background.

DISPLAY: The 1550 scoreboard displays inning by inning scores from 1 to 10 for the GUEST and HOME teams, total RUNS and HITS to 99, total ERRORS to 9, BATTER number to 99, BALLS, STRIKES, OUTS, HIT, and ERROR.

DIGITS AND INDICATORS: Red light emitting diodes mounted on printed circuit boards form the digits and indicators. The BATTER number, BALL, STRIKE, OUT digits are 18" tall. The inning scores, total RUNS, HITS, and ERRORS digits, hit (H) indicator, and error (E) indicator are 15" tall.

POWER REQUIREMENTS: Scoreboard - 120 VAC, 3.2 A, 60 Hz. Control Console - 120 VAC, 0.5 A, 60 Hz

SCOREBOARD ELECTRONICS: 100% solid state fully enclosed.

CONTROL CONSOLE: The control console features a microprocessor, 37 key sealed membrane keypad, a LCD display and an attached 6 foot power cord. The console housing consists of ABS plastic base and top pieces with a steel back plate.

CONTROL CABLE: The cable has two 22 AWG stranded copper conductors with semi-rigid PVC insulation. It also has a braided shield and a foil shield. The polyethylene jacket is rated at 300 volts. The cable is direct burial rated and measures approximately 1/4" in diameter. This item is sold separately from the scoreboard.

JUNCTION BOX AND EXTENSION CABLE: A 4 1/4" x 2 1/4" x 2" junction box with a 1/4" stereo jack mounted on the face plate is attached to the control cable at the point of operation. A 10 ft. extension cable connects the control console to the junction box.

SCORELINK 300 RF MODEM SYSTEM: This accessory can be used in place of control cable and junction box for this scoreboard without internal modifications to the scoreboard or the control console. Refer to the SCORELINK 300 RF MODEM SYSTEM OWNER'S HANDBOOK for more information.

WARRANTY: Five year limited warranty.

SCOREBOARD INSTALLATION

This part of the manual describes the mechanical and electrical installation of the scoreboard.

One of the items listed below must be purchased in order to complete the installation:

- Control cable (length dependent upon installation site layout)
- ScoreLink 300 RF Modem System

Items not provided by Electro-Mech Scoreboard Company that are necessary for installation:

- Three posts
- Power cable to connect the scoreboard to the power source
- Grounding hardware
- A grounded NEMA 5-15R 120 VAC receptacle for the control console at the scorekeeper's table.

Items not provided that are recommended by Electro-Mech Scoreboard Company for installation:

- A weatherproof power disconnect at the scoreboard

Electro-Mech Scoreboard Company performs installations in some areas. In other areas, we can help you contact an independent installer. In areas in which installation service is not available from Electro-Mech Scoreboard Company, we will make every effort to answer your installation questions. Qualified personnel should perform the scoreboard installation. Consult national and local codes before installation.

MECHANICAL INSTALLATION

The mechanical installation includes installing the posts and mounting the scoreboard and the optional top sponsor panels (if purchased) to the posts.

Post Installation

The scoreboard mounts on three posts. Typically installers will use steel pipes or I-beams. In order to reduce the glare from the sun on the front of the scoreboard, position the posts so that the front of the scoreboard is angled away from the afternoon sun, if possible. The mounting hardware will accommodate posts up to 7 inches outer diameter. Sink the posts in reinforced concrete footings. Figure 1 shows the spacing of the posts for a 1550 scoreboard. The specifications for the posts and concrete footings are dependent upon the expected local wind and soil conditions, the height of the scoreboard from the ground, and the local building codes. Electro-Mech Scoreboard Company assumes no responsibility for the installation of scoreboards by others.




Figure 1 1550 Post Spacing

Figure 2 shows the spacing of the posts for a 1550 scoreboard with an optional top sponsor panel. This panel is a separate unit that mounts on the same posts as the scoreboard.




Figure 2 1550 with Optional Top Sponsor Panel Post Spacing

Figure 3 shows the spacing of the posts for a 1550 with side sponsor panel. The side sponsor panel is a separate assembly that bolts to the side of the scoreboard.




Figure 3 1550 with Optional Side and Top Sponsor Panel Post Spacing

Mounting The Scoreboard

The scoreboard is attached to the posts at twelve points. Figure 4 shows the location of the mounting points on the rear of the scoreboard.




Figure 4 Mounting Points

MOUNTING HARDWARE

Twelve sets of mounting hardware are provided to attach the scoreboard at these points. Additional hardware sets are provided to attach the optional sponsor panels, if ordered. A single set of mounting hardware for the scoreboard consists of a steel angle bracket, two threaded rods, two washers, and two nuts. A single set of mounting hardware for an optional top sponsor panel consists of a steel angle bracket, two threaded rods, four washers, and four nuts. Figure 5 shows an overhead cross section view and a side cross section view of the scoreboard attached to a post at a mounting point. A steel bar is riveted inside the scoreboard's aluminum extrusion frame. The bar has two tapped holes. The threaded rods screw into these tapped holes. The washers and nuts are used to clamp the steel angle bracket against the steel post and hold the scoreboard in place.




Figure 5 Standard Mounting Method

The following steps describe how to mount the scoreboard on the posts:

1. Place the lower section of the scoreboard against the posts on the ground. Make sure the mounting points are aligned with the posts.
2. If the eyebolts are installed in the upper section of the scoreboard, unscrew them and screw them into the lower section of the scoreboard.
3. Screw the threaded rods into the tapped holes in the scoreboard.
4. Place a steel angle bracket over the threaded rods at a mounting point.
5. Place a washer over each threaded rod.
6. Screw the nuts onto the threaded rods so that the bracket is **loosely** held in place.
7. Repeat steps 4 -6 at the other mounting points.
8. Raise the section into place and tighten the nuts to clamp it in place on the posts.
9. Unscrew the eyebolts from the lower section of the scoreboard and screw them into the upper section of the scoreboard.
10. Place the upper section of the scoreboard on top of the lower section.
11. Attach the mounting hardware by the same method as the lower section.
12. Tighten the nuts to clamp it in place on the posts.

Mounting The Optional Side Sponsor Panel

If you purchased the optional side sponsor panel, the scoreboard has been modified so that the sponsor panel bolts to the side of the scoreboard cabinet. Four bolts and washers are provided to attach the side sponsor panel to the scoreboard. The following steps describe how to attach the sponsor panel to the scoreboard and mount the optional side sponsor panels on the posts:

1. There are four small access panels on the rear of the side sponsor panel. Remove these access panels.
2. Position the sponsor panel next to the scoreboard.
3. Screw the threaded rods into the tapped holes at one of the sponsor panel mounting points.
4. Place a steel angle bracket over the threaded rods at the mounting point.
5. Place a washer over each threaded rod.
6. Screw the nuts onto the threaded rods so that the bracket is loosely held in place.
7. Repeat steps 3 - 6 at the other mounting point.
8. Place a washer over a bolt.
9. Insert the bolt into the top sponsor access panel opening and through the hole in the frame.
10. Screw the bolt into the tapped hole in the scoreboard cabinet.
11. Repeat steps 8-10 at the other three access panel openings.
12. Tighten the nuts to clamp the sponsor panel in place on the post.
13. Re-install the access panels.

Mounting The Optional Top Sponsor Panel

Additional hardware sets are provided to attach the optional top sponsor panels, if purchased. The following steps describe how to mount the top sponsor panel on the posts:

1. Raise the top sponsor panel in place above the scoreboard. Make sure the mounting points are aligned with the posts.
2. Place the threaded rods through the mounting holes in the top sponsor panel at one mounting point.
3. Place a washer over each threaded rod inside the frame of the top sponsor panel, and screw a nut onto each threaded rod behind the washers inside the frame of the top sponsor panel.
4. Place a steel angle bracket over the threaded rods at a mounting point.
5. Place a washer over each threaded rod.
6. Screw a nut onto each threaded rod so that the bracket is loosely held in place.
7. Repeat steps 2 - 6 at the other mounting points.
8. Tighten the nuts to clamp it in place on the posts.

ELECTRICAL INSTALLATION

We recommend a qualified electrician perform the needed electrical connections to ensure proper operation of the scoreboard. These connections include grounding the scoreboard, the upper scoreboard cabinet power and data connections, connecting the scoreboard to a power source, installing the ScoreLink 300 or the control cable, and connecting the control console.

Ground Connection

The National Electrical Code **requires** a scoreboard (electric sign) to be grounded. Grounding the scoreboard helps the scoreboard electronics operate properly and helps minimize damage if it is struck by lightning. Metal posts do **not** provide an adequate ground path. The following steps describe how to connect the scoreboard to the power source:

1. Drive one or more 5/8" x 8' copper clad ground rods in the soil near the scoreboard.
2. Connect #6 bare copper wire to the ground rods using 5/8" brass tear drop connectors.
3. Remove the rear access panels and the dome plugs on the plates below the access panels. Figure 6 shows the location of the access panels and the dome plugs.




Figure 6 Rear Access Panels

4. Connect the ground conductor to the ground lugs located behind the access panels.

Power Connections to Upper Scoreboard Cabinet

The following steps describe how to connect power to the upper scoreboard cabinet:

1. There is a cable attached to the upper access panel terminal block labeled **Power from Bottom Section**. Feed the cable through one of the holes in the plate below the access panel.
2. Install the cable in conduit and feed the cable through one of the holes in the plate below the lower access panel.
3. Connect the cable to the terminal block labeled **Power to Top Section** according to Figure 7.




Figure 7 Power to Top Section Connections

Control Cable Connections to Upper Scoreboard Cabinet

The following steps describe how to connect data to the upper scoreboard cabinet:

1. There is a cable attached to the upper access panel terminal block labeled **Control from Bottom Section**. Feed the cable through one of the holes in the plate below the access panel.
2. Install the cable in conduit and feed the cable through one of the holes in the plate below the lower access panel.

3. Connect the cable to the terminal block labeled **Control to Top Section** according to Figure 8.




Figure 8 Control to Top Section Connections

4. Reinstall the upper access panel.

Power Connection to Scoreboard

The scoreboard requires 120 VAC service at the scoreboard to operate properly. **Maximum power consumption of Model 1550: 384 Watts.** Make sure that power cable is rated for this electrical load. Install the power cable in conduit. **Avoid** running the power cable in close proximity to the control cable. The following steps describe how to connect the scoreboard to the power source:

1. Feed the power cables through a hole in the plate below the lower access panel.
2. Crimp fork terminals to the power cable wires.
3. Connect the AC line wire and AC neutral wire to the **Main Power** terminal block on the junction chassis according to Figure 9.




Figure 9 Power to Scoreboard Connections


Install a power disconnect that isolates all current carrying conductors on one of the posts below the scoreboard (not the ground conductor). If a secondary switch is installed near the scorekeeper's table, it should also isolate these conductors. Place the power disconnect in the **OFF** position between games to help protect the scoreboard from lightning damage. A power disconnect on the scoreboard post also provides a convenient way of turning the scoreboard off during maintenance or repairs.

ScoreLink 300

The ScoreLink 300 RF MODEM SYSTEM is designed to eliminate the control cable between the scoreboard and the control console on Electro-Mech Scoreboard MM and MP series scoreboards as well as all LED scoreboards. If you have purchased this accessory, disregard the section of this manual titled **Control Cable Installation**. Refer to the ScoreLink 300 RF MODEM SYSTEM OWNER'S HANDBOOK for installation instructions.

Control Cable Installation

The control cable connects the scoreboard to the control console. Install the control cable in conduit. If the cable is ever damaged, it is easier and less expensive to replace a cable in conduit. A small junction box with a ¼" stereo jack mounted on the face plate is attached to the control cable at the point of operation of the scoreboard. This junction box should be securely mounted in a clean, dry area within ten feet of the rear of the control console. Most customers order the control cable with the junction box attached. Some customers prefer to attach the junction box after the cable is installed. Those customers must solder the control cable to the ¼" stereo jack. Figure 10 shows the control cable wire connection points on the rear of the ¼" stereo jack.



PIN 1 - BLACK WIRE
 PIN 2 - RED WIRE
 PIN 3 - SHIELD WIRE

Figure 10 ¼" Stereo Jack Wiring Diagram

The following steps describe how to connect the control cable to the scoreboard:

1. At the rear of the scoreboard feed the control cable one of the holes in the plate below the lower access panel.
2. Crimp fork terminals to the control cable wires and the shield.
3. Connect the control cable to **Control Cable** terminal block on the lower access panel junction chassis according to Figure 11.




Figure 11 Control Cable Wiring Diagram

4. Reinstall the lower access panel.

Control Console Connections

The 10 ft. extension cable has two molded ¼” stereo plugs attached to it. It is used to connect the control console to the junction box. The following steps describe how to connect the control console:

1. Plug one end of the extension cable into ¼” stereo jack on the junction box or the ScoreLink 300 Transmitter, if purchased.
2. Plug the other end into the ¼” stereo jack mounted on the control console back plate.
3. Plug the control console power cord into a grounded NEMA 5-15R 120 VAC receptacle.

Control Console Safety Warning

This product is equipped with a 3-wire grounding type plug, a plug having a third (grounding) pin. This plug will only fit into a grounding-type power outlet. This is a safety feature. If you are unable to insert the plug into the outlet, contact a qualified electrician to replace your obsolete outlet. Do not defeat the purpose of the grounding-type plug.

SCOREBOARD OPERATION**SCOREBOARD STARTUP**

1. Place the power disconnect for the scoreboard in the **ON** position.
2. Plug one end of the extension cable into ¼” stereo jack on the junction box or the ScoreLink 300 Transmitter, if purchased.
3. Plug the other end into the ¼” stereo jack mounted on the control console back plate.
4. Plug the control console power cord into a grounded NEMA 5-15R 120 VAC receptacle.
5. If a ScoreLink 300 RF MODEM SYSTEM is installed with this scoreboard, plug the wall mount DC power supply into a grounded NEMA 5-15R 120 VAC receptacle and the male plug on the end of the attached cable into the Power jack on the Transmitter.

GAME TIME OPERATION

This scoreboard is operated with a 37-key control console. Figure 12 shows the keypad layout on the control console.




Figure 12 Keypad Layout

Immediately after the control console power cord is plugged into a 120 VAC source, the console LCD display will read:

ELECTRO-MECH 2. 1 SCOREBOARD MPB15

After a few seconds the display will read:

OO D15: OO OO I NNI NG -

The scoreboard will display:

BATTER – 0
GUEST RUNS – 0
GUEST HITS – 0
GUEST ERRORS – 0
HOME RUNS – 0
HOME HITS – 0
HOME ERRORS – 0

The control console LCD display shows the total runs for the HOME and GUEST teams. It also provides instructions to help the operator use some of the console functions. Note: The runs scored for each inning, total HITS, total ERRORS, BATTER number, BALLS, STRIKES, OUTS, HITS, and ERRORS will be displayed on the scoreboard, but not on the console. There is a clock function displayed on the control console, not on the scoreboard. Figure 13 explains the LCD display layout.




Figure 13 Control Console LCD Display

Control Console Key Functions

1. **INC INNING T / B** – This key increments the inning to the next half inning. When the console is turned on, the LCD display will read:

```
00 D15: 00 00
I NNI NG -
```

Press [INC INNING T / B]. The LCD display will then read:

```
00 D15: 00 00
I NNI NG 01 TOP
```

The console is set to the top of the first inning. Pressing the key again increments the console to the bottom of the first inning.

2. **ASSIGN ERROR** – This key is display the position of the player that committed an error. To assign the error to a player position, press [ASSIGN ERROR]. The console LCD display will read:

```
00 D15: 00 00
ERR POSI TI ON<00>
```

Press [4], [ENTER] on the control console. The scoreboard will flash E4 four times to indicate that position 4 committed an error.

3. **SET BATTER** – Press [SET BATTER]. The LCD display will read:

00	D15:	00	00
BATTER			<00>

Press [1][3][ENTER] to set the BATTER number to 13.

4. **SET TOTAL RUNS** – Press [SET TOTAL RUNS]. The LCD display will read:

00	D15:	00	00
TOT RUNS TOP			<00>

Press [3][ENTER] to set the GUEST runs to 3. The LCD display will then read:

00	D15:	00	00
TOT RUNS BOT			<00>

Press [2][ENTER] to set the Home runs to 2.

5. **SET TOTAL HITS** – Press [SET TOTAL HITS]. The LCD display will read:

00	D15:	00	00
TOT HI TS TOP			<00>

Press [4][ENTER] to set the GUEST hits to 4. The LCD display will then read:

00	D15:	00	00
TOT HI TS BOT			<00>

Press [5][ENTER] to set the Home runs to 5.

6. **SET TOTAL ERRORS** – Press [SET TOTAL ERRORS]. The LCD display will read:

00	D15:	00	00
TOT ERRS TOP			<00>

Press [7][ENTER] to set the GUEST errors to 7. The LCD display will then read:

00	D15:	00	00
TOT ERRS BOT			<00>

Press [1][ENTER] to set the Home errors to 1.

7. **RUNS +1** – This key will increment the total runs by 1.
8. **HITS +1** – This key will increment the total hits by 1. The Hit indicator (H) will flash four times.
9. **ERRORS +1** – This key will increment the total errors by 1. The Error indicator (E) will flash four times.
10. **BALLS +1** – This key will increment the Balls by 1.
11. **STRIKES +1** – This key will increment the Strikes by 1.
12. **OUTS +1** – This key will increment the Outs by 1.

13. **SET INNING T / B** – This key is used to change the current inning. Press [SET INNING T / B] and the LCD display will read:

OO	D15:	OO	OO
SET	TO	INN	<00>

Press [5], [ENTER] to change to the fifth inning. The LCD display will read:

OO	D15:	OO	OO
TOP=0	/BOT=1		<00>

Press [1], [ENTER] to select the bottom of the inning. The LCD display will read:

OO	D15:	OO	OO
INN	NG	05	BOTTOM

14. **CLEAR / FLASH HITS** – This key has two purposes. It can be used to clear incorrect keypad entries. It can also be used to flash the hit indicator (H) on the scoreboard.
15. **ENTER / FLASH ERRORS** – This key has two purposes. It is used when entering game information. It can also be used to flash the error indicator (E) on the scoreboard.
16. **SET RUNS / INNING** – This key is used to change the score in a previous inning. Press [SET RUNS / INNING] and the LCD display will read:

OO	D15:	OO	OO
RUNS-	INN	NG	<05>

Press [3], [ENTER] to set the runs in the third inning. The LCD display will read:

OO	D15:	OO	OO
RUNS-	TOP		<02>

Press [1], [ENTER] to change the score for the top of the third inning. The LCD display will read:

OO	D15:	OO	OO
RUNS-	BOTTOM		<02>

Press [2], [ENTER] to change the score for the bottom of the third inning. **Note:** The total runs will not be updated automatically on the scoreboard or the control console. You must use the SET TOTAL RUNS key to update this information.

17. **NEW GAME** – This key is used to reset all the scoreboard functions to their default settings. To reset the scoreboard, press [NEW GAME]. The console LCD display will read:

RESET	YES<1>
SCOREBOARD	NO<0>

Press [1], [ENTER] on the control console. The scoreboard will reset its functions.

The SET CLOCK, SET CLOCK .1 SEC, .1 SEC ON / OFF, CLOCK UP / DOWN, AUTO HORN, TIME OF DAY, HORN ON / OFF, CLOCK ON/OFF, and DIMMER keys are not used with the 1550 scoreboard.

You should reset the scoreboard each time that it is turned on. Test out all the functions to ensure that the scoreboard is operating properly.

SCOREBOARD SHUTDOWN

1. Place the power disconnect for the scoreboard in the **OFF** position.
2. Unplug the control console power cord.
3. Unplug the extension cable.
4. If a ScoreLink 300 RF MODEM SYSTEM is installed with this scoreboard, unplug the Transmitter's wall mount power supply.
5. Store the control console and ScoreLink 300 Transmitter in a dry location. These units are not waterproof.

Proper scoreboard shutdown will help protect the scoreboard and control console from power surges and lightning strikes.

SERVICING THE SCOREBOARD

While your scoreboard was designed for years of trouble-free operation, some problems may occasionally occur. Electro-Mech Scoreboard Company offers onsite service in some areas. In other areas, we can help you contact an independent service technician. In areas in which service is not available from Electro-Mech Scoreboard Company, we will make every effort to answer your questions. Our trained personnel at Electro-Mech Scoreboard Company are ready to answer your questions from Monday to Friday during the hours of 8 AM to 5 PM Eastern Standard Time. Be sure to know your scoreboard model number when calling. Scoreboard replacement parts are always available. Damaged parts can usually be repaired at a significant cost savings. Our convenient toll free number is listed at the bottom of every page in this manual.

TROUBLESHOOTING TIPS

Before calling Electro-Mech Scoreboard Co. for customer support of a scoreboard problem, it is helpful to make note of all the symptoms. If the scoreboard does not turn on LEDs, please check the following items:

1. Make sure the control console power cord and the extension cable are plugged.
2. Verify that the control console LCD display shows game information.
3. Press control console keys and look for changes on the game information shown on the LCD display.
4. Check the circuit breaker that supplies power to the scoreboard.
5. Remove the lower scoreboard cabinet rear access panel cover and check the voltages present at **Main Power** terminal block.
6. Check the fuses on the LPS5 and LPS7 Power Supply Modules.
7. Make sure all wire and ribbon cable connections are plugged in securely.
8. Take the control console and the 10 ft. extension cable to the scoreboard. Temporarily disconnect the control cable from the **Control Cable** terminal block and plug the 10 ft. extension cable into the test jack on the LPS5 Power Supply Module. Plug the control console power cord into the 120 VAC receptacle on the left side of the LPS5 Power Supply Module. If the LEDs are now illuminated and the scoreboard reacts to control console entries, there may be a problem with the control cable or the ScoreLink 300 modem, if purchased.

If the scoreboard turns on LEDs, but does not operate normally, make note of which functions are affected. If some LEDs either never turn on or always stay on, make note of their specific locations on the scoreboard. Refer to the COMPONENT REPLACEMENT section of this manual before changing parts.

COMPONENT REPLACEMENT

LED digits are serviced from the front of the scoreboard. All other components are located behind the rear access panels.

LED Digits And Indicators Replacement

The LEDs that form digits and indicators are soldered on circuit boards mounted behind metal masks. Do not attempt to replace individual LEDs. In case of a malfunction, the entire LED circuit board must be removed. **To avoid damage to the LED driver module, always turn off the power to the scoreboard when removing or replacing LED digits and indicators.** Figure 14 shows the components of a LED digit assembly. LED indicator assemblies are similar in construction.





Figure 14 LED Digit Assembly

1. Remove the sheet metal screws that fasten the mask to the face of the scoreboard. **Caution: Support the mask before removing the last screw. The ribbon cable that connects to the rear of the circuit board is not designed to support the weight of the assembly.**
2. Disconnect the ribbon cable from the rear of the circuit board. **Caution: Do not let the cable hang outside of the scoreboard. It is easily cut by sharp metal edges. Damage to the ribbon cable may create short circuit paths that will damage the LED driver module.**
3. Place the assembly on a flat surface and remove the 6-32 kep lock nuts that hold the circuit board in place.
4. Remove the circuit board.
5. Align the mounting holes in the circuit board with the threaded studs on the mask and install the replacement digit on the mask.
6. Plug the ribbon cable onto the header on the back of the circuit board. Refer to Figure 15 in order to plug the ribbon cable IDC connector onto the circuit board in the proper orientation.



CENTER KEY ON RIBBON CABLE IDC SOCKET
MUST POINT IN THE SAME DIRECTION AS THE
ARROW ON THE REAR OF THE LED DIGIT.

Figure 15 LED Digit Ribbon Cable Connection Diagram

LED Digit Driver - Large Boards are used when the current requirements of the scoreboard exceed the capacity of a LED Driver Module. These circuit board assemblies are mounted on standoffs behind LED digits, as needed. In case of a malfunction, the entire circuit board must be removed. **To avoid damage to the scoreboard electronics, always turn off the power to the scoreboard when removing or replacing LED Digit Driver - Large Boards. Observe proper handling procedures to prevent static damage to these circuit boards.** The table below lists the LED Digit Driver - Large Boards in this scoreboard and their functions.

LED DIGIT DRIVER - LARGE BOARD	FUNCTION #1	FUNCTION #2
GUEST INNING 1 DIGIT	GUEST INNING 1 DIGIT	
HOME INNING 1 DIGIT	HOME INNING 1 DIGIT	

Figure 16 shows a LED Digit Driver – Large Board mounted behind a LED digit.




Figure 16 LED Digit Driver - Large Board

LED Digit Driver - Large Board Replacement

1. Remove the sheet metal screws that fasten the mask to the face of the scoreboard. **Caution: Support the mask before removing the last screw. The wires and cables that connect to the rear of the LED digit and LED Digit Driver – Large Board are not designed to support the weight of the assembly.**
2. Disconnect the ribbon cables from the rear of the LED digit and LED Digit Driver – Large Board. **Caution: Do not let the cables hang outside of the scoreboard. Ribbon cables easily cut by sharp metal edges. Damage to a ribbon cable may create short circuit paths that will damage the LED driver module.**
3. Disconnect the wire assembly from the LED Digit Driver – Large Board J1 jack.
4. Place the assembly on a flat surface and remove the 6-32 kep lock nuts that hold the LED Digit Driver – Large Board in place.
5. Remove the old circuit board.
6. Align the mounting holes in the new circuit board with the standoffs and install the replacement circuit board.
7. Fasten the circuit board in place with the 6-32 kep lock nuts.

All other components are located behind the rear access panels. Figure 17 shows the view behind the lower access panel.




Figure 17 Lower Access Panel Components

LDM16 LED DRIVER MODULE FUNCTIONS

DRIVER MODULE JACK	FUNCTION
J1	DRIVER MODULE DC POWER INPUT #1
J2	SERIAL DATA INPUT
J3	SERIAL DATA OUTPUT
J4	HOME RUNS UNITS DIGIT
J5	HOME RUNS TENS DIGIT
J6	HOME HITS UNITS DIGIT
J7	HOME INNING 1 LED DIGIT DRIVER - LARGE BOARD J20
J8	HOME INNING 2 DIGIT
J9	HOME INNING 3 DIGIT
J10	HOME INNING 7 DIGIT
J11	HOME INNING 8 DIGIT
J12	HOME INNING 9 DIGIT
J13	DRIVER MODULE DC POWER INPUT #2
J17	HOME HITS TENS DIGIT
J18	HOME ERRORS DIGIT
J19	HOME INNING 5 DIGIT
J20	HOME INNING 4 DIGIT
J21	HOME INNING 6 DIGIT
J23	HOME INNING 10 DIGIT

Note: All other LDM16 jacks are unused.

LDM17 LED DRIVER MODULE FUNCTIONS

DRIVER MODULE JACK	FUNCTION
J1	DRIVER MODULE DC POWER INPUT #1
J2	SERIAL DATA INPUT
J3	SERIAL DATA OUTPUT
J4	GUEST RUNS UNITS DIGIT
J5	GUEST RUNS TENS DIGIT
J6	GUEST HITS UNITS DIGIT
J7	GUEST INNING 1 LED DIGIT DRIVER - LARGE BOARD J20
J8	GUEST INNING 2 DIGIT
J9	GUEST INNING 3 DIGIT
J10	GUEST INNING 7 DIGIT
J11	GUEST INNING 8 DIGIT
J12	GUEST INNING 9 DIGIT
J13	DRIVER MODULE DC POWER INPUT #2
J17	GUEST HITS TENS DIGIT
J18	GUEST ERRORS DIGIT
J19	GUEST INNING 5 DIGIT
J20	GUEST INNING 4 DIGIT
J21	GUEST INNING 6 DIGIT
J23	GUEST INNING 10 DIGIT

Note: All other LDM17 jacks are unused.

LED Driver Modules Replacement

Electrical connections to the LED DRIVER MODULES are made with ribbon cable polarized IDC sockets and locking ramp crimp terminal housings that mate with jacks on the module. The module is secured inside the scoreboard with four machine screws.

1. Unplug the electrical connections from the module. Do not cut the plastic tie wraps around the ribbon cables.
2. Remove the four screws.
3. Remove the module from the scoreboard.
4. Insert the replacement module in the scoreboard.
5. Secure the module with the four screws.
6. Insert the plugs into the jacks on the module.

To avoid damage to the module, always turn off the power to the scoreboard when removing or replacing it.

LPS5 LED POWER SUPPLY MODULE FUNCTIONS

JACK	FUNCTION
J1	120 VAC INPUT
J2	20 VDC OUTPUT TO LED POWER INTERFACE BOARD
J3	SERIAL DATA INPUT / OUTPUT
J4	NOT USED
J5	SERIAL DATA TEST JACK

A relay inside the LPS5 Power Supply Module isolates the LDM16 LED Driver Module from the control cable when the scoreboard is shut down. Connecting the control console to the test jack on the LPS5 Power Supply Module (J5) with the 10 ft. extension cable bypasses this relay. Figure 18 shows the location of the fuses in the LPS5 LED Power Supply Module. The table following the figure lists the fuse ratings, functions, and part numbers.




Figure 18 LPS5 Fuse Locations

LPS5 FUSES

FUSE	RATING	FUNCTION	BUSSMAN PART #
F1	3A 250V	TRANSFORMER PRIMARY	AGC-3
F2	5A 250V	LED POWER INTERFACE BOARD J1	AGC-5
F3	5A 250V	LED POWER INTERFACE BOARD J6	AGC-5
F4	1/2A 250V	SERIAL DATA ISOLATION RELAY	AGC-1/2
F5	1A 250V	NOT USED	AGC-1
F6	1/2A 250V	120 VAC ELECTRICAL RECEPTACLE	AGC-1/2

Note: Other manufacturers' fuses may be substituted for the Bussmann fuses.

LPS7 LED POWER SUPPLY MODULE FUNCTIONS

JACK	FUNCTION
J1	120 VAC INPUT
J2	20 VDC OUTPUT TO LED POWER INTERFACE BOARD

Figure 19 shows the location of the fuses in the LPS7 LED Power Supply Module. The table following the figure lists the fuse ratings, functions, and part numbers.




Figure 19 LPS7 Fuse Locations

LPS7 FUSES

FUSE	RATING	FUNCTION	BUSSMAN PART #
F1	3A 250V	TRANSFORMER PRIMARY	AGC-3
F2	5A 250V	LED POWER INTERFACE BOARD J11	AGC-5
F3	5A 250V	LED POWER INTERFACE BOARD J16	AGC-5

Note: Other manufacturers' fuses may be substituted for the Bussmann fuses.

LED Power Supply Modules Replacement

Electrical connections to the LED POWER SUPPLY MODULES are made with keyed plugs that mate with jacks on the left side of the module. The module is secured inside the scoreboard with four machine screws.

1. Disconnect the plugs from the four jacks on the module.
2. Remove the four screws.
3. Remove the module from the scoreboard.
4. Insert the replacement module in the scoreboard.
5. Secure the module with the four screws.
6. Insert the plugs into the jacks on the side of the module.

To avoid damage to the module, always turn off the power to the scoreboard when removing or replacing it.

The LED Power Interface board distributes the output from the power supply modules to the LDM16 and LDM17 LED driver modules and the LED digit driver – large board assemblies.

LED Power Interface Board Replacement

1. Unplug the wire assemblies from the jacks on the circuit board.
2. The circuit board is mounted on snap-in standoffs. Unseat the circuit board from the standoffs.
3. Press the replacement circuit board in place on the standoffs.
4. Plug the wire assemblies in the correct jacks on the circuit board. Each wire assembly is labeled to indicate the correct jack connection.

Figure 20 shows the view behind the upper access panel.




Figure 20 Upper Access Panel Components

LDM18 LED DRIVER MODULE FUNCTIONS

DRIVER MODULE JACK	FUNCTION #1
J1	DRIVER MODULE DC POWER INPUT
J2	SERIAL DATA INPUT
J3	NOT USED
J4	BATTER UNITS DIGIT, H
J5	BATTER TENS DIGIT
J6	BALL DIGIT, E
J7	NOT USED
J8	OUT DIGIT
J9	STRIKE DIGIT
J10	ERROR NUMBER DIGIT

LPS6 LED POWER SUPPLY MODULE FUNCTIONS

JACK	FUNCTION
J1	120 VAC INPUT
J2	20 VDC OUTPUT TO LED POWER INTERFACE BOARD
J3	SERIAL DATA INPUT / OUTPUT
J4	NOT USED
J5	SERIAL DATA TEST JACK

Connecting the control console to LPS6 test jack (J5) with the 10 ft. extension cable enables the operation of the upper section of the scoreboard from the upper access panel. Disconnect the cable wires that are connected to the bottom of the terminal block labeled **Data from Bottom Section**. Figure 21 shows the location of the fuses in the LPS6 LED Power Supply Module. The table following the figure lists the fuse ratings, functions, and part numbers.




Figure 21 LPS6 Fuse Locations

LPS6 FUSES

FUSE	RATING	FUNCTION	BUSSMAN PART #
F1	3A 250V	TRANSFORMER PRIMARY	AGC-3
F2	5A 250V	LED POWER INTERFACE BOARD J1	AGC-5
F3	5A 250V	LED POWER INTERFACE BOARD J6	AGC-5
F4	1A 250V	12 VDC RELAY OUTPUT (NOT USED ON THIS SCOREBOARD)	AGC-1
F5	1A 250V	12 VDC RELAY OUTPUT (NOT USED ON THIS SCOREBOARD)	AGC-1
F6	½A 250V	120 VAC ELECTRICAL RECEPTACLE	AGC-1/2

Note: Other manufacturers' fuses may be substituted for the Bussmann fuses.

ELECTRO-MECH SCOREBOARD CO. FIVE YEAR LIMITED WARRANTY

THE ELECTRICAL COMPONENTS OF ALL ELECTRO-MECH SCOREBOARDS ARE GUARANTEED FOR A PERIOD OF FIVE (5) YEARS FROM THE DATE OF INVOICE AGAINST DEFECTS IN WORKMANSHIP OR MATERIAL AND WILL BE REPLACED OR REPAIRED WITHOUT COST TO THE OWNER PROVIDED THE EQUIPMENT OR PARTS ARE RETURNED POSTAGE-PAID TO THE FACTORY IN WRIGHTSVILLE, GA. SHIPPING BACK TO THE OWNER WILL BE VIA UPS GROUND SERVICE EXCEPT WHEN AIR OR SPECIAL METHOD OF RETURN IS SPECIFIED BY THE OWNER, IN WHICH CASE SHIPPING WILL BE FREIGHT COLLECT.

EXCLUDED FROM THIS WARRANTY ARE FUSES.

THIS WARRANTY DOES NOT INCLUDE LABOR CHARGES INCURRED IN THE REMOVAL OF COMPONENT PARTS, SERVICE CALLS, OR DAMAGES RESULTING FROM IMPROPER INSTALLATION, IMPROPER OPERATION, OR PROBLEMS CAUSED BY ANY REPAIR, ALTERATION OR MODIFICATION OF THE SCOREBOARD NOT PERFORMED BY ELECTRO-MECH.

EQUIPMENT WHICH IS SUBJECTED TO ACCIDENT, NEGLIGENCE, ABUSE, MISUSE OR OTHER NATURAL DISASTERS, INCLUDING BUT NOT LIMITED TO FIRE, WIND, LIGHTNING, OR FLOOD, IS NOT COVERED BY THIS GUARANTEE.